

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010356-R3
DATE: 09/14/2010
CERTIFICATION PROGRAM: Structural
COMPANY: Lepage Millwork
CODE: 422-1
REVISION DATE: 08/30/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Lepage Millwork 141 Chemin Des Raymond Riviere-Du-Loup, Quebec G5R 4L9	Series "Wind Zone 3" Double Hung Weight & Chain Wood Prime Window Configuration: X/X Glazing: IG-4mm Tempered Glass/Laminate- 4mm Annealed Glass/0.090" DuPont Sentry Glass Plus Interlayer/4mm Annealed Glass Frame: W-1165mm(45.88") H-1937mm(76.25") Sash: W-968mm(38.13") H-981mm(38.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-02/05/E1996-02/05	C-LC70 914 x 1816 (36 x 72) Design Pressure: +70/-70 psf Wind Zone 3-Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-12960-1
Expiration Date: June 30, 2026

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122