

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010414.01-R6
DATE: 12/01/2010
CERTIFICATION PROGRAM: Structural
COMPANY: Huttig
CODE: 893-1
REVISION DATE: 04/09/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Huttig Building Products 2115 Valley View Lane Farmers Branch, TX 75234	Series "Smooth Star" Glazed Fiberglass Side-Hinged Entry Door w/Sidelites Frame: Wood or Composite Configuration: OXO Glazing: Insulating Glass(Tempered) Frame: W-2845mm(112") H-2083mm(82") Panel: W-914mm(36") H-2013mm(79.25") Sidelite: W-914mm(36") H-2013mm(79.25") STP: Pos+48.0 psf Neg-48.0 psf

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-12 Federal Manufactured Home Construction & Safety Standard 3280.305	Manufactured Housing - Passed Wind Zone II/Wind Zone III (Wind Zone III-All areas except 3'0" from endwall or sidewall)

Product Tested By: Architectural Testing, Inc.
Report No: A4929.01-501-47/W-1465
Expiration Date: October 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023