

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010424.02-R5  
**DATE:** 12/10/2010  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1411-1  
**REVISION DATE:** 02/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>“Premium Series Mira Casement”</b>  <b>Out-Swing Aluminum Clad</b>  <b>Wood Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-914mm(36.0") H-2159mm(85") DLO: W-772mm(30.37") H-2016mm(79.37")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class LC-PG50 914 x 2159 (36 x 85)-C</b> <b>C-LC50 914 x 2159 (36 x 85)</b> <b>Design Pressure: 2392 Pa (50 psf)</b> <b>Negative Design Pressure: 3110 Pa (65 psf)</b> <b>Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-12765-3/W-2010  
Expiration Date: August 31, 2030

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)