NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI010474.02-R3**
DATE:	**06/20/2018**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**05/14/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**Series "4712FIR/4712FLIR/4812FIR"** **Aluminum Single Hung Window** Configuration: O/X Glazing: IG-1/8" Annealed/Laminate-1/8" Annealed/0.090" Interlayer by Eastman/1/8" Annealed Glass Frame: W-1219mm(48") H-2134mm(84") Sash: W-1171mm(46.12") H-899mm(35.37")

SPECIFICATION	PRODUCT RATING
AAMA 506-08/11/16 **ASTM E1886-02/05/13a** **ASTM E1996-02/05/09/14a** **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class LC-PG50 1219 x 2134 (48 x 84)-H** **H-LC50 1219 x 2134 (48 x 84)** **Design Pressure: ±2400 Pa (±50 psf)** **Positive Design Pressure: 2633 Pa (55 psf)** **Negative Design Pressure: 2873 Pa (60 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)** **Impact Rating:** **Design Pressure: +50/-57 psf** **Wind Zone 3-Missile Level D**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-13482-1/NCTL-110-13259-1/NCTL-110-13264-1/W-1958
Expiration Date: **November 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Email: nami@namiinc.com