

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010485-R4  
DATE: 01/24/2011  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> 433 North Main Street Rocky Mount, VA 24151	<b>“XT Series”</b> <b>Direct Set Vinyl Picture Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1524mm(60") H-2438mm(96") DLO: W-1448mm(57") H-2362mm(93")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	<b>Class CW-PG45 1524 x 2438 (60 x 96)</b> <b>FW-C45 1524 x 2438 (60 x 96)</b> <b>Design Pressure: ±2160 Pa (45 psf)</b> Water Penetration Resistance Test Pressure: 580 Pa(12.0 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: 310-1416(EOA0)/W-2047  
Expiration Date: **January 31, 2029**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)