

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010510-R6  
DATE: 02/11/2011  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 08/06/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>“Builders Series 1111 Integral Mull”</b> <b>Vinyl Single Hung Prime Window</b> <b>Fin Frame Triple Integral Mull</b>  Configuration: OX/OX/OX Glazing: Insulating Glass (Annealed)  Frame: W-2729mm(107.4) H-1816mm(71.5") Sash: W-832mm (32.75") H-889mm (35")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class R-PG35 2729 x 1816 (107 x 72)-H</b> <b>H-R35 2729 x 1816 (107 x 72)</b> <b>Design Pressure: 2155 Pa (45 psf)</b> <b>Negative Design Pressure: 2394 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 251 Pa(5.25 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-12919-1/W-1886/W-2010/W-2159  
Expiration Date: March 31, 2030

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023