NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI010523-R4
DATE: 02/11/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 07/09/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**"Builder Series 1181 Sliding Door"** **Vinyl Sliding Glass Door** Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-2425mm(95.5") H-2425mm(95.5") Panel: W-1207mm(47.5") H-2359mm(92.87")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class R-PG15 2425 x 2425 (96 x 96)-SD** **SD-R15 2425 x 2425 (96 x 96)** **Design Pressure: 718 Pa (15 psf)** **Negative Design Pressure: 958 Pa (20 psf)** **Water Penetration Resistance Test Pressure: 287 Pa (6.0 psf)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-13512-1/W-2047
Expiration Date: **November 30, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com