

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010574-R6  
DATE: 03/22/2011  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 08/06/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>“MW Pro Series Classic/5000 Awning”</b> <b>Out-Swing Vinyl Awning Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-1207mm(47.50") H-902mm(35.50") Vent: W-1156mm(45.50") H-852mm(33.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	<b>Class LC-PG50 1207 x 902 (48 x 36)-AP</b> <b>AP-LC50 1207 x 902 (48 x 36)</b> <b>Design Pressure: ±2394 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 431 Pa(9.0 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-13639-1/W-2010/W-2112  
Expiration Date: February 28, 2030

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)