

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010627.02-R5
DATE: 05/13/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 11/20/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	“Mira Out-Swing Panel Stationary” Aluminum Clad Wood Fixed Door Configuration: OO Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer 1/8" Annealed Glass Frame: W-1911mm(75.25") H-2491mm(98.06") Panel: W-914mm(36") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 AAMA 506-06 ASTM E1886-02/05/E1996-02/05	Class R-PG50 1911 x 2491 (75 x 96)-FD FD-R50 1911 x 2491 (75 x 96) Design Pressure: ±2394 Pa (±50 psf) Wind Zone 3 - Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-13907-1/W-2010
Expiration Date: **April 30, 2030**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023