NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI010636-R4
DATE: 05/16/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1
REVISION DATE: 01/27/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. **2000 Locust Gap Highway** **Mount Carmel, PA 17851**	**Series "5100" Vinyl Impact Rated** **Tilt Single Hung Prime Window** Configuration: O/X Glazing: IG-Interior-1/8" Tempered Glass/ Exterior-Laminate-1/8" Annealed Glass/0.090" PVB Interlayer by DuPont/1/8" Annealed Glass Frame: W-1016mm(40") H-1676mm(66") Sash: W-940mm(37") H-794mm(31.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 **AAMA/WDMA/CSA 101/I.S.2/A440-05** **ASTM E1886-02/05/E1996-02/05** **TAS 201/202/203-94**	**Class R-PG55 1016 x 1676 (40 x 66)-H** **H-R55 1016 x 1676 (40 x 66)-H** **Design Pressure: 2633 Pa (55 psf)** **Negative Design Pressure: 3352 Pa (70 psf)** **Wind Zone 4-Missile Level D** **Large Missile Impact Rated** **Water Penetration Resistance Test Pressure: 400 Pa (8.25 psf)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-13718-1/NCTL-110-13718-2/NCTL-110-13718-3/W-1901/ W-1979
Expiration Date: **April 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122