

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010671.01-R5
DATE: 05/24/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Millwork Plus
CODE: 1784-1
REVISION DATE: 11/06/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Millwork Plus, Inc. 262 Hummer Way Tavares, FL 32778	Series "VGDF" Wood Entry Glazed Single In-Swing & Out-Swing Door w/Sidelites & Half Round Transom Configuration: O/OXO Sidelite/Transom Glazing: 1/4 Tempered Etched Glass Frame: W-2261mm(89") H-3708mm(146") Panel: W-914mm(36") H-2451mm(96.5") TR DLO: W-2184mm(86") H-1067mm(42")

SPECIFICATION	PRODUCT RATING
ASTM E330-14	Design Pressure: ±2873 Pa (±60 psf)

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1836W-2/W-1531/W-2135
Expiration Date: **January 31, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.M.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023