

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010680-R8
DATE: 06/20/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Sun-Tek
CODE: 225-1
REVISION DATE: 08/18/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sun-Tek Manufacturing, Inc. 10303 General Drive Orlando, FL 32824	Series "CMG II" Aluminum Glazed Skylight Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1664mm(65.5") H-2578mm(101.5") DLO: W-1524mm(60") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class CW-PG60 1664 x 2578 (66 x 102)-RWG Class CW-PG60 1664 x 2578 (66 x 102)-SKG-RW SKG/RW-C60 1664 x 2578 (66 x 102)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3676-1/W-1969
Expiration Date: **September 30, 2027**

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com