

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010696-R6  
DATE: 07/11/2011  
CERTIFICATION PROGRAM: Structural  
COMPANY: Hoelscher  
CODE: 1765-1  
REVISION DATE: 01/15/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Hoelscher Weatherstrip Manufacturing Company, Inc.</b> <b>2400 S. Persimmon St.</b> <b>Tomball, TX 77375</b>	<b>“Mahogany 3/4 Lite Inswing Door”</b> <b>Glazed Wood Side-Hinged Entrance Door</b>  Configuration: X  Schlage JH58 Lockset w/Steel Security Plate/ Kwikset 687DA Glazing: Insulating Glass (Tempered)  Frame: W-1111mm(43.75") H-2483mm(97.75") Panel: W-1067mm(42") H-2413mm(95") DLO: W-676mm(26.63") H-1680mm(66.13") STP: Pos+2916 Pa (60.9 psf) Neg-3821 Pa (79.8 psf)

SPECIFICATION	PRODUCT RATING
<b>ASTM E330-02</b>	<b>Overall Design Pressure: 40 psf</b> <b>Negative Design Pressure: -53 psf</b>

Product Tested By: Architectural Testing, Inc.  
Report No: A7368.03-801-44  
Expiration Date: **February 28, 2027**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)