

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010735-R6  
**DATE:** 09/21/2011  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 11/21/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>“MW Pro Classic Series”</b> <b>Tilt Twin Vinyl Double Hung Window</b> <b>w/Integral Mullion</b>  Configuration: OX//O/X Glazing: Insulating Glass (Annealed)  Frame: W-1937mm(76.25") H-1653mm(65.06")  Panel: W-884mm(34.8") H-735mm(28.93")  STP: Pos+2770 Pa (58 psf) Neg-2770 Pa (58 psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA 1701.2-95/02</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b> <b>AAMA 1704-85/95/01</b>	<b>Manufactured Housing-Passed</b> <b>Wind Zone III</b> <b>Egress-Passed</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-14189-1/W-1889/W-1919  
Expiration Date: **June 30, 2025**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)