

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010735.01-R6
DATE: 09/21/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 11/21/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	“MW Pro Classic Series” Tilt Triple Vinyl Double Hung Window w/Integral Mullion Configuration: OX//O/X//O/X Glazing: Insulating Glass (Annealed) Frame: W-2911mm(114.62") H-1654mm(65.12") Panel: W-883mm(34.75") H-813mm(32") STP: Pos+2290 Pa (48 psf) Neg-2290 Pa (48 psf)

SPECIFICATION	PRODUCT RATING
AAMA 1701.2-95/02 Federal Manufactured Home Construction & Safety Standard 3280.305 AAMA 1704-85/95/01	Manufactured Housing-Passed Wind Zone II Egress-Passed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14189-2/W-1889/W-1919
Expiration Date: **June 30, 2025**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com