

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010742.01-R2  
DATE: 10/31/2011  
CERTIFICATION PROGRAM: Structural  
COMPANY: The Door Store  
CODE: 1367-1  
REVISION DATE: 04/02/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>The Door Store of America DBA</b> <b>DSA Master Crafted Doors, LLC</b> <b>10681 World Trade Boulevard</b> <b>Raleigh, NC 27617</b>	<b>“Wakefield 1LT Pair” One Lite</b> <b>Rectangle Top Double Wood Doors</b>  Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1892mm(74.5") H-2515mm(99") Panel: W-914mm(36") H-2438mm(96") DLO: W-634mm(24.97") H-1672mm(65.84")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04/E330-02</b>	<b>Design Pressure: +50/-50 psf</b>

Product Tested By: American Test Lab, Inc.  
Report No: ATLNC-0721.01-11/EE-Smith 2011-10-04 Dwg DSA #012-2011  
Expiration Date: **February 28, 2026**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023