

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010742.06-R2
DATE: 11/02/2011
CERTIFICATION PROGRAM: Structural
COMPANY: The Door Store
CODE: 1367-1
REVISION DATE: 04/02/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| The Door Store of America DBA DSA Master Crafted Doors, LLC 10681 World Trade Boulevard Raleigh, NC 27617 | “Tiffany TDL 4LT Arch Top Pair” Four Lite Arch Top Double Wood Doors Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1892mm(74.5") H-2515mm(99") Panel: W-914mm(36") H-2438mm(96") DLO: W-306mm(12.06") H-794mm(31.25") |

| SPECIFICATION | PRODUCT RATING |
|-----------------------------|-------------------------------------|
| ASTM E283-04/E330-02 | Design Pressure: +50/-50 psf |

Product Tested By: American Test Lab, Inc.
Report No: ATLNC-0721.01-11/EE-Smith 2011-10-03 Dwg DSA #006-2011
Expiration Date: **February 28, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023