

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010747-R4  
DATE: 09/30/2011  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 02/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>“Premium Series Mira”</b> <b>Aluminum Clad Wood</b> <b>Sliding Glass Door</b>  Configuration: OXXO Glazing: Insulating Glass (Tempered)  Frame: W-3572mm(140.62") H-2511mm(98.87") Panel: W-911mm(35.87") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class LC-PG50 3556 x 2515 (141 x 99)-SD</b> <b>SD-LC50 3556 x 2515 (141 x 99)</b> <b>Design Pressure: 2394 Pa (50 psf)</b> <b>Negative Design Pressure: 2394 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-14336-1/W-2010  
Expiration Date: August 31, 2030

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023