

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010747.01-R5  
**DATE:** 09/30/2011  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 11/20/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>“Premium Series Mira”</b> <b>Aluminum Clad Wood</b> <b>Sliding Glass Door</b>  Configuration: XOO Glazing: Insulating Glass (Tempered)  Frame: W-3672mm(144.56") H-2511mm(98.87") Panel: W-1219mm(48") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class LC-PG50 3672 x 2511 (145 x 99)-SD</b> <b>SD-LC50 3715 x 2511 (145 x 99)</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-14341-1/W-2010  
Expiration Date: June 30, 2030

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023