

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010760.02-R4  
**DATE:** 10/27/2011  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 03/03/2022

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "Mira Impact" Aluminum</b> <b>Clad Wood Impact Rated Quarter Circle</b> <b>Out-Swing Casement Window</b>  Configuration: X Glazing: IG-1/8" Annealed Glass/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass  Frame: W-716mm(28.19") H-1972mm(77.62") DLO: W-565mm(22.25") H-1822mm(71.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA 506-06/08/11</b> <b>ASTM E1886-02/05/E1996-02/05</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Design Pressure: +50/-50 psf</b> <b>Wind Zone 3-Missile Level D</b> <b>Positive Design Pressure: +50 psf</b> <b>Negative Design Pressure: -57 psf</b> <b>C-R50</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-14371-1/NCTL-110-12765-2  
Expiration Date: September 30, 2026

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)