

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI010760.03-R4</u>
DATE:	<u>11/02/2011</u>
CERTIFICATION PROGRAM:	<u>Structural</u>
COMPANY:	<u>Ply Gem</u>
CODE:	<u>1408-1</u>
REVISION DATE:	<u>03/03/2022</u>

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151</p>	<p style="text-align: center;">Series "Mira Impact" Aluminum Clad Wood Impact Rated True Radius Out-Swing Casement Window</p> <p style="text-align: center;">Configuration: X Glazing: IG-1/8" Annealed Glass/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass</p> <p>Frame: W-914mm(36") H-2286mm(90") DLO: W-768mm(30.25") H-2135mm(84.06")</p>

SPECIFICATION	PRODUCT RATING
<p>AAMA 506-06/08/11 ASTM E1886-02/05/E1996-02/05 AAMA/WDMA/CSA 101/I.S.2/A440-05</p>	<p>Design Pressure: +50/-50 psf Wind Zone 3-Missile Level D Positive Design Pressure: +50 psf Negative Design Pressure: -57 psf C-LC50</p>

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14372-1/NCTL-110-12765-5
Expiration Date: **October 31, 2026**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com