

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010783-R4
DATE: 11/15/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Natural Light
CODE: 557-1
REVISION DATE: 02/07/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Natural Light Energy Systems 10821 North 23rd Avenue, #1 Phoenix, AZ 85029	“Natural Light/Venti/Solar Attic Fan” Self Flash Roof Mounted Attic Ventilation Fan w/Solar Panel

SPECIFICATION	PRODUCT RATING
ASTM E330-02/TAS 202-94 TAS 100(A)-95	Design Pressure: +86.5 psf/-120.0 psf Maximum Wind Speed w/No Vent Displacement: 110 mph Total Volume of Infiltrated Water: 0 ml

Product Tested By: Architectural Testing, Inc./PRI Construction Materials Technologies
Report No: A8071.01-301-44/A8071.02-301-18/NLES-001-02-02
Expiration Date: August 31, 2029

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com