

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010790-R4  
DATE: 11/22/2011  
CERTIFICATION PROGRAM: Structural  
COMPANY: American  
CODE: 1582-1  
REVISION DATE: 02/17/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Skylites 525 113 <sup>th</sup> Street Arlington, TX 76011	Series "BVCM-2" Acrylic Double Dome Thermally-Broken Aluminum Fixed Barrel Vault Curb Mount Skylight Inner Dome: 1/8" Acrylic Outer Dome: 3/16" Acrylic Base Opening: W-2438mm(96") H-3658mm(144")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG30 2438 x 3658 (96 x 144)-SKP

Product Tested By: Architectural Testing, Inc.  
Report No: A9823.01-801-44  
Expiration Date: July 31, 2029

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi".

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)