

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010823.01-R4
DATE: 09/30/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Tapco
CODE: 1247-1
REVISION DATE: 05/30/2023

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
TAPCO, Inc. 1815 McCullough Boulevard Tupelo, MS 38801	Series "300-12" Pivot Hurricane Screen Configuration: O/X 0.035" Stainless Steel Mesh Frame: W-1321mm(52") H-2134mm(84") Panel: W-1168mm(46") H-940mm(37")

SPECIFICATION	PRODUCT RATING
ASTM E330-02 ASTM E1886-02/05/E1996-02/05 TAS 201/202/203-94	Design Pressure: +50/-50 psf Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories.
Report No: NCTL-210-3737-1A/W-1719
Expiration Date: May 31, 2025

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122