NOTICE OF PRODU	<b>JCT CERTIFICA</b>	ΓION ———
CCREDIT		
4 TOES NO ACCREDIT AD		
Non and A	<b>CERTIFICATION NO:</b>	NI010891.02-R2
	DATE:	02/27/2012
CERT	FICATION PROGRAM:	Structural
TA ACCOUNTS THE	<b>COMPANY:</b>	<b>Door Store</b>
CERTIFIED BRODUCT	CODE:	1367-1
. TED FRO	<b>REVISION DATE:</b>	04/02/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
The Door Store of America DBA	"Briarcliff" Wood Door	
DSA Master Crafted Doors, LLC		
10681 World Trade Boulevard	Configuration: X	
Raleigh, NC 27617	Glazing: Insulating Glass (Tempered)	
	Frame: W-1118mm(44") H-2558mm(100.7")	
	Panel: W-914mm(36") H-2438mm(96")	
	Max DLO: W-210mm(8.25") H-311mm(12.25")	

SPECIFICATION	PRODUCT RATING
ASTM E283-04/ASTM E330-02	Design Pressure: +50/-50 psf

Product Tested By:American Test Lab, Inc.Report No:ATLNC-1107.01-11/EE-Smith 2012-01-31 Dwg DSA #007-2012/W-1506Expiration Date:February 28, 2026

Sh

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023