

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010891.08-R2  
**DATE:** 02/27/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Door Store  
**CODE:** 1367-1  
**REVISION DATE:** 04/02/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>The Door Store of America DBA DSA Master Crafted Doors, LLC 10681 World Trade Boulevard Raleigh, NC 27617</b>	<b>“Santa Barbara One Lite” Wood Door with One Lite Sidelites and One Lite Transom</b>  Configuration: O/OXO  Glazing: Insulating Glass (Tempered)  Frame: W-1905mm(75") H-2583mm(101.7") Panel: W-914mm(36") H-2438mm(96") Max DLO: W-307mm(12.1") H-524mm(20.6")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04/ASTM E330-02</b>	<b>Design Pressure: +50/-50 psf</b>

Product Tested By: American Test Lab, Inc.  
Report No: ATLNC-1107.01-11/EE-Smith 2012-01-31 Dwg DSA #005-2012/W-1506  
Expiration Date: **February 28, 2026**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'Shi'.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)