

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010897.05-R4
DATE: 01/12/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1
REVISION DATE: 06/19/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, VA 26104 | Series "400/500/5400/5400S" Vinyl Single Hung Window Configuration: O/X Glazing: Insulated Glass (Annealed) Frame: W-914mm(36") H-2032mm(80") DLO: W-860mm(33.88") H-989mm(38.94") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-05 | Class LC-PG50 914 x 2032* (36 x 80*)-H H-LC50 914 x 2032 (36 x 80) Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) |

Product Tested By: Architectural Testing, Inc.
Report No: 80901.02-501-47/W-1920
Expiration Date: **March 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com