

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010903.07-R7  
**DATE:** 01/30/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Wincore  
**CODE:** 1640-1  
**REVISION DATE:** 07/12/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wincore Window Company, LLC</b> <b>250 Staunton Turnpike</b> <b>Parkersburg, WV 26104</b>	<b>Series "5400/5400S/7700/9900"</b> <b>Vinyl Sliding Glass Door</b>  Configuration: OX  Glazing: IG-Exterior-3mm Tempered Glass/Laminate-3mm Annealed Glass/0.8 mm Solutia Interlayer/ 3mm Annealed Glass or Insulating Glass (Tempered)  Frame: W-2400mm(94.5") H-2019mm(79.5")  Panel: W-1201mm(47.28") H-1911mm(75.24")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class R-PG40 2400 x 2019 (95 x 80)-SD</b> <b>SD-R40 2400 x 2019 (95 x 80)</b> <b>Design Pressure: 1920 Pa (40 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 330 Pa (6.75 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: Air-Ins, Inc.  
Report No: AI-03288-A1 Rev. 1/V-201009/W-1920/W-2050  
Expiration Date: **January 31, 2029**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)