NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI011006-R2
DATE: 03/13/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Therma-Tru
CODE: 052-1
REVISION DATE: 03/23/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation **118 Industrial Drive** **Edgerton, OH 43517**	**Opaque Fiberglass "Impact"** **Door in Masonry Opening** Configuration: X Frame: W-953mm(37.75") H-2045mm(80.5") Panel: W-915mm(36") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94 **ASTM E330-02** **ASTM E1886-02/E1996-02**	**Design Pressure: +65/-65 psf** **Wind Zone 4-Missile Level D** **Large Missile Impact Rated**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01460144/TEL-06-1031-1-Revised
Expiration Date: **March 31, 2036**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com