

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011023.03-R4
DATE: 07/13/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 01/16/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "700" Vinyl Casement Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1524mm(60") Vent: W-889mm(35") H-1499mm(59")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CMBSO 1-79/CAWM 300-89	Class CW-PG40 914 x 1524 (36 x 60)-C C-C40 914 x 1524 (36 x 60) Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 580 Pa(12.0 psf) Canadian Air Infiltration/Exfiltration Rate: A2

Product Tested By: National Certified Testing Laboratories
Report No: 310-2565/W-1724
Expiration Date: **April 30, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com