

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011055-R4
DATE: 04/09/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Window Crafts.
CODE: 690-1
REVISION DATE: 11/26/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman 6031 Clark Center Avenue Sarasota, FL 34238	Series "SH-300" Vinyl Single Hung Window (Nail Fin, Screw & Strap Installation) Configuration: O/X Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" DuPont Butacite Interlayer/ 1/8" Annealed Glass Frame: W-1321mm(52") H-1905mm(75") Sash: W-1251mm(49.25") H-940mm(37")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-02/05/13a/E1996-02/05/14a TAS 201/202/203-94	Class LC-PG70 1321 x 1905 (52 x 75)-H H-LC70 1321 x 1905 (52 x 75) Design Pressure: ±3360 Pa (70 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14896-1/110-14896-2/110-14896-3/110-14896-4/110-14896-5
W-1965
Expiration Date: **February 28, 2030**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023