

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011056-R4  
**DATE:** 04/09/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Window Crafts.  
**CODE:** 690-1  
**REVISION DATE:** 11/26/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsmen</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>Series "SS-300"</b> <b>Vinyl Horizontal Sliding Window</b>  Configuration: XO Nail Fin, Screw & Strap Installation  Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" DuPont Butacite Interlayer/ 1/8" Annealed Glass  Frame: W-1880mm(74") H-1600mm(63") Panel: W-921mm(36.25") H-1524mm(60")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b> <b>ASTM E1886-02/05/13a/E1996-02/05/14a</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Design Pressure: +50/-50 psf</b> <b>Wind Zone 2-Missile Level D</b> <b>HS-LC50 1880 x 1600 (74 x 63)</b> <b>Class LC-PG50 1880 x 1600 (74 x 63)-HS</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-14897-1/110-14897-2/110-14897-3/14897-4/110-14897-5/  
W-1965

Expiration Date: August 31, 2030

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023