NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI011067-R3
DATE: 04/23/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 10/24/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**"XT 960 Series"** **Vinyl Sliding Glass Door** Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1930mm(76") H-2438mm(96") Panel: W-960mm(37.81") H-2365mm(93.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05** **CMBSO 1-79/CAWM 300-89**	**Class R-PG25 1930 x 2438 (76 x 96)-SD** **SD-R25 1930 x 2438 (76 x 96)** **Design Pressure: ±1200 Pa (25 psf)** **Water Penetration Resistance Test Pressure: 290 Pa(6.0 psf)** **Canadian Air Infiltration/Exfiltration Rate: A3**

Product Tested By: National Certified Testing Laboratories
Report No: 310-2370/W-2047
Expiration Date: **February 28, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com