

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011077.01-R3
DATE: 04/25/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 10/30/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "Crusader" Vinyl Double Hung Window Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-2134mm(84") Sash: W-845mm(33.25") H-1038mm(40.8")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 914 x 2134 (36 x 84)-H

Product Tested By: Architectural Testing, Inc.
Report No: B0027.01-801-47/68770.01-801-47
Expiration Date: May 31, 2033

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com