NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011109.01-R8**
DATE:	**05/21/2012**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Loewen**
CODE:	**1862-1**
REVISION DATE:	**07/14/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen **77 Highway 52 West** **Steinbach, Manitoba R5G 1B2**	**Series "25" Aluminum Clad Wood** **Double Hung Fixed Window** Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-3048mm(120") H-1524mm(60") DLO: W-2877mm(113.25") H-1489mm(58.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class LC-PG55 3048 x 1524 (120 x 60)-FW** **FW-LC55 3048 x 1524 (120 x 60)** **Design Pressure: 2640 Pa (55 psf)** **Negative Design Pressure: 2640 Pa (55 psf)** **Water Penetration Resistance Test Pressure: 400 Pa (8.25 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Architectural Testing, Inc.
Report No: A6170.01-201-44/W-1567/W-1818/W-2116/W-2129
Expiration Date: **December 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com