

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011109.02-R7  
DATE: 05/21/2012  
CERTIFICATION PROGRAM: Structural  
COMPANY: Loewen  
CODE: 1862-1  
REVISION DATE: 09/12/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Loewen</b> <b>77 Highway 52 West</b> <b>Steinbach, Manitoba R5G 1B2</b>	<b>Series "25" Aluminum Clad Wood</b> <b>Double Hung Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1422mm(56")      H-1930mm(76") Sash: W-1340mm(52.75")      H-1854mm(73")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class LC-PG55 1422 x 1930 (56 x 76)-FW</b> <b>FW-LC55 1422 x 1930 (56 x 76)</b> <b>Design Pressure: 2640 Pa (55 psf)</b> <b>Negative Design Pressure: 3120 Pa (65 psf)</b> <b>Water Penetration Resistance Test Pressure: 400 Pa (8.25 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: Fixed</b>

Product Tested By: Architectural Testing, Inc.  
Report No: A6172.02-201-44/W-1567/W-1818/W-2116/W-2129  
Expiration Date: **December 31, 2026**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)