

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011120.03-R5  
**DATE:** 05/28/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Milliken  
**CODE:** 997-1  
**REVISION DATE:** 11/21/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Milliken Millwork, Inc.</b>  <b>172 Plummer Road</b>  <b>Sidman, PA 15955</b>	<b>“Single Door w/Sidelites and Transom”</b>  <b>Inswing Fiberglass Glazed Door</b>  <b>Composite/Vinyl Clad Frame Assembly</b> <b>w/Sidelites &amp; Transom</b>  Configuration: O/OXO Glazing: Insulating Glass (Tempered)  Frame: W-1740mm(68.50)    H-2350mm(92.5")  Panel: W-909mm(35.75")    H-2000mm(78.75")  SL:    W-352mm(13.87")    H-2016mm(79.37") TR:    W-279mm(11.00")    H-2350mm(92.50")

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-02</b> <b>Federal Register Manufactured Home</b> <b>Construction &amp; Safety Standards 3280.409</b>	<b>Federal Manufactured Housing-Passed</b> <b>Wind Zone III</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-14667-1  
Expiration Date: December 31, 2024

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)