

# NOTICE OF PRODUCT CERTIFICATION




**CERTIFICATION NO:** NI011158.03-R4  
**DATE:** 06/22/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1411-1  
**REVISION DATE:** 07/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> 433 North Main Street Rocky Mount, VA 24151	<b>“Contractor Series 2000/HarborLight/ Home Craftsman 8125/Mastic 3000” Vinyl Horizontal Sliding Window</b>  Configuration: XX Glazing: Insulating Glass (Annealed)  Frame: W-1829mm(72") H-1422mm(56.06") Panel: W-881mm(34.68") H-1335mm(52.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CMBSO 1-79/CAWM 300-89	<b>Class LC-PG40 1829 x 1422 (72 x 56)-HS HS-LC40 1829 x 1422 (72 x 56) Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 360 Pa(7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-14984-4/W-2071  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)