

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011158.07-R4
DATE: 06/22/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1411-1
REVISION DATE: 07/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	“Contractor Series 2000/HarborLight/ Home Craftsman 8125/Mastic 3000” Vinyl Horizontal Sliding Window Configuration: XXX Glazing: Insulating Glass (Annealed) Frame: W-3759mm(148") H-1222mm(48.13") Panel: W-1832mm(72.13") H-1130mm(44.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CMBSO 1-79/CAWM 300-89	Class R-PG20 3759 x 1222 (148 x 48)-HS HS-R20 3759 x 1222 (148 x 48) Design Pressure: 960 Pa (20 psf) Water Penetration Resistance Test Pressure: 260 Pa(5.43 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14984-8/W-2071
Expiration Date: **January 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com