

# NOTICE OF PRODUCT CERTIFICATION



**Company:** Wincore Window Company, LLC  
 250 Staunton Avenue  
 Parkersburg, WV 26104

**Certification No.:** NI011161.03-R1  
**Certification Date:** 06/25/2012  
**Expiration Date:** 04/30/2029  
**Revision Date:** 02/18/2025

**Product:** Series “Ohio” Impact Rated & Non-Impact Rated Glazed & Opaque Fiberglass Doors  
 w/ & w/o Impact Rated Glazed Sidelites (W/ Wood Frame Unless Specified)

**Specification:** TAS 201-94/202-94/203-94

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
XX Double	O/S	Glazed	6'2" x 6'9"	+50/-50	9.00 psf	Yes	TEL 01390365.1 (Specimens 49 & 50) Max Panel Size: 3'0" x 6'8"/Daylight Opening: 1'9" x 5'3" Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Saflex PVB/1/8" Annealed Glass w/Schlage Latch & Deadbolt, Endura Multipoint Astragal, Endura Standard Bump Threshold, & Composite Jamb Qualifies Configurations:X/XX
XX Double	I/S	Glazed	6'2" x 6'10"	+50/-50	0.00 psf	Yes	TEL 01390365.1 (Specimens 39 & 40) Max Panel Size: 3'0" x 6'8"/Daylight Opening: 1'9" x 5'3" Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Saflex PVB/1/8" Annealed Glass w/Pamex Latch & Deadbolt, Columbia Hurricane Astragal, Columbia Inswing Saddle Threshold, & Composite Jamb Qualifies Configurations:X/XX
XX Double	O/S	Glazed	6'2" x 6'9"	+65/-65	9.75 psf	Yes	TEL 01390365.1 (Specimens 27 & 28) Max Panel Size: 3'0" x 6'8"/Daylight Opening: 1'9" x 5'3" Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Saflex PVB/1/8" Annealed Glass w/Schlage Latch & Deadbolt, DLP Hurricane Astragal, DLP High Dam Bump Threshold, & Composite Jamb Qualifies Configurations: X/XX
XX Double	O/S	Glazed	6'2" x 6'9"	+75/-75	11.25 psf	Yes	TEL 01390365.1 (Specimens 33 & 34) Max Panel Size: 3'0" x 6'8"/Daylight Opening: 1'9" x 5'3" Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Saflex PVB/1/8" Annealed Glass w/W & F 3-Point MP Hardware, DLP Hurricane Astragal, DLP High Dam Bump Threshold, & Wood Jamb Qualifies Configurations:X/XX

**National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072**

**Tel: (804) 684-5124/Email: [nami@namiinc.com](mailto:nami@namiinc.com)**

**NAMI AUTHORIZED SIGNATURE:** \_\_\_\_\_