

# NOTICE OF PRODUCT CERTIFICATION



**Company:** Wincore Window Company, LLC  
 250 Staunton Avenue  
 Parkersburg, WV 26104

**Certification No.:** NI011161.05-R1  
**Certification Date:** 06/25/2012  
**Expiration Date:** 04/30/2029  
**Revision Date:** 02/18/2025

**Product:** Series “Ohio” Impact Rated & Non-Impact Rated Glazed & Opaque Fiberglass Doors w/ & w/o Impact Rated Glazed Sidelites (W/ Wood Frame Unless Specified)

**Specification: TAS 201-94/202-94/203-94**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
OXXO Double w/Sidelites	I/S	Opaque	12’8” x 6’10”	+40/-60	0.0 psf	No	TEL 01390365.1 (Specimen 7) Max Panel Size: 3’0” x 6’8”/Daylight Opening: 1’9” x 5’3” Glazing: IG-1/8” Tempered Glass/Laminate-1/8” Annealed Glass/0.090” Solutia Saflex PVB/1/8” Annealed Glass w/Schlage Latch & Deadbolt, Columbia Standard Astragal w/ 2-1/4” Bolts, Columbia Saddle Threshold, & Composite Jamb with 2x Mullion Qualifies Configurations:O/X//OX/XO/OXO/OXX/XXO/OXXO
OXXO Double w/Sidelites	O/S	Opaque	12’8” x 6’9”	+50/-50	9.0 psf	Yes	TEL 01390365.1 (Specimens 3 & 4) Max Panel Size: 3’0” x 6’8”/Daylight Opening: 1’9” x 5’3” Glazing: IG-1/8” Tempered Glass/Laminate-1/8” Annealed Glass/0.090” Solutia Saflex PVB/1/8” Annealed Glass w/W & F 3-Point Hardware, Columbia Hurricane Astragal, Columbia High Dam Threshold, & Wood Jamb w/2x Mullion Qualifies Configurations:O/X//OX/XO/OXO/OXX/XXO/OXXO
OXXO Double w/Sidelites	O/S	Opaque	12’8” x 6’9”	+50/-50	9.0 psf	Yes	TEL 01390365.1 (Specimens 5 & 6) Max Panel Size: 3’0” x 6’8”/Daylight Opening: 1’9” x 5’3” Glazing: IG-1/8” Tempered Glass/Laminate-1/8” Annealed Glass/0.090” Solutia Saflex PVB/1/8” Annealed Glass w/W & F 3-Point Hardware, Columbia Hurricane Astragal, Columbia Standard Bump Threshold, & Composite Jamb w/ 2x Mullion Qualifies Configurations:O/X//OX/XO/OXO/OXX/XXO/OXXO

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072  
 Tel: (804) 684-5124/Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NAMI AUTHORIZED SIGNATURE: \_\_\_\_\_