

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011184.02-R5
DATE: 07/09/2012
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 01/21/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	Precedence[®] Horizontal Sliding Vinyl Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-2439mm(96") H-1524mm(60") Vent: W-1204mm(47.38") H-1423mm(56") DLO: W-1118mm(44") H-1336mm(52.56")

SPECIFICATION	PRODUCT RATING
ASTM E283-04(2012) ASTM E330-02/14 ASTM 547-00 ASTM F588-04	Design Pressure: 1197 Pa (25 psf) Negative Design Pressure: 1197 Pa (25 psf) Water Penetration Resistance Test Pressure: 252 Pa (5.25 psf) FER-Passed Grade 10

Product Tested By: Hurricane Testing Laboratories
Report No: G231-0202-09 /W-2075/W-2179
Expiration Date: **December 31, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com