

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011185.08-R4
DATE: 07/30/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 11/06/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "Pro 200 Horizontal Slider" Vinyl Horizontal Sliding Window Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-3048mm(120") H-1829mm(72") Panel: W-727mm(28.63") H-1765mm(69.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CMBSO 1-79/CAWM 300-89	Class R-PG15 3048 x 1829 (120 x 72)-HS HS-R15 3048 x 1829 (120 x 72) Design Pressure: ±720 Pa (15 psf) Water Penetration Resistance Test Pressure: 220 Pa(4.5 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Quality Testing, Inc.
Report No: NS2010-377/NS2010-381/W-2047
Expiration Date: June 30, 2029

A handwritten signature in black ink, appearing to be "Shi".

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023