

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011247-R6
DATE: 09/04/2012
CERTIFICATION PROGRAM: Structural
COMPANY: QMI
CODE: 691-1
REVISION DATE: 01/16/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
QMI Security Solutions 1661 Glenlake Avenue Itasca, IL 60143	Series "Stormsafe" Aluminum Operable Impact Screen (HVHZ & Non-HVHZ) Configuration: X Screen: 304 Stainless Steel (0.060") Frame: W-1638mm(64.5") H-3747mm(147.5") DLO: W-1435mm(56.5") H-3543mm(139.5")

SPECIFICATION	PRODUCT RATING
ASTM E330-02 ASTM E1886-02/04/E1996-02/04 TAS 202-94 (Structural Only) TAS 201/203-94	Design Pressure: +47/-53 psf Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1366W-3/CTLA-1366W/W-1888
Expiration Date: **September 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

