## NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI011259.01-R5

**DATE:** 09/06/2012

CERTIFICATION PROGRAM: <u>Structural/Impact</u>

COMPANY: Bildau & Bussman

CODE: <u>1651-1</u>

**REVISION DATE:** 02/28/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="https://www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bildau & Bussmann GmbH	"Fixed Sash/Mulled Fenestration"
Gerichtstrasse 23	Wood Mulled Fixed Window
13347 Berlin, Germany	Configuration: OO/O
	Glazing: Monolithic-Laminate-1/4" Tempered Glass/0.090" DuPont SGP/1/4" Tempered Glass or IG- 1/4" Tempered Glass/Laminate-1/4" Tempered Glass /0.090" DuPont SGP/1/4" Tempered Glass
	Frame: W-4572mm(180") H-3048mm(120")
	DLO: W-2113mm(83.19") H-2879mm(113.32")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +70/-70 psf Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-210-3800-1

Expiration Date: <u>June 30, 2027</u>

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023