NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011270-R3**
DATE:	**09/14/2012**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Regency**
CODE:	**750-1**
REVISION DATE:	**12/09/2021**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. **2000 Locust Gap Highway** **Mount Carmel, PA 17851**	**Series "6412"** **Vinyl Horizontal Sliding Window** Configuration: XO Glazing: IG-Interior-1/8" Tempered Glass/ Exterior-Laminate-1/8" Annealed Glass/0.090" DuPont PVB Interlayer/1/8" Annealed Glass Frame: W-1880mm(74") H-1600mm(63") Panel: W-921mm(36.25") H-1524mm(60)

SPECIFICATION	PRODUCT RATING
ASTM E1886-04/E1996-04 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Design Pressure: +45/-50 psf** **Wind Zone 4-Missile Level D** **Class LC-PG50 1880 x 1600 (74 x 63)-HS** **HS-LC50 1880 x 1600 (74 x 63)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15257-1/NCTL-110-15257-2/W-1979
Expiration Date: **August 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com