

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011273-R5  
**DATE:** 09/14/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Solar  
**CODE:** 872-1  
**REVISION DATE:** 11/12/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Solar Innovations, Inc.</b>  <b>31 Roberts Road</b>  <b>Pine Grove, PA 17963</b>	<p style="text-align: center;"><b>Series "SI 3350 Impact FGW 3x8 Panel"</b></p> <p style="text-align: center;"><b>Out-Fold Aluminum Reinforced</b></p> <p style="text-align: center;"><b>Folding Glass Wall</b></p> <p style="text-align: center;">Configuration: XXXXXX</p> <p>Glazing: IG-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" Sentry Glass Plus/3/16" Heat Strengthened Glass and/or IG-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.060" Sentry Glass Plus/3/16" Heat Strengthened Glass and/or Monolithic-3/16" Heat Strengthened Glass/0.090" Sentry Glass Plus/3/16" Heat Strengthened Glass</p> <p>Frame:    W-5664mm(223")    H-2553mm(100.5")</p> <p>Panel:     W-915mm(36")        H-2438mm(96")</p> <p>DLO:      W-737mm(29")        H-2261mm(89")</p>

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<p style="text-align: center;"><b>Design Pressure: +80/-80 psf</b></p> <p style="text-align: center;">Water Penetration Resistance Test Pressure: 430 Pa (9.0 psf)</p> <p style="text-align: center;"><b>Large Missile Impact Rated</b></p>

Product Tested By: National Certified Testing Laboratories  
 Report No: NCTL-110-15005-1  
 Expiration Date: **August 31, 2031**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124/Email: [nami@namiinc.com](mailto:nami@namiinc.com)