

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011273.02-R4  
**DATE:** 12/12/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Solar  
**CODE:** 872-1  
**REVISION DATE:** 11/12/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Solar Innovations, Inc.</b>  <b>31 Roberts Road</b>  <b>Pine Grove, PA 17963</b>	<b>Series "SI 3350 Impact FGW 3x 8 Panel"</b>  <b>Radius In-Swing Aluminum</b>  <b>Folding Glass Wall</b>  Configuration: XXXXXX  Glazing: IG-3/16" Tempered Glass (Exterior)/Laminate-3/16" Tempered Glass/0.090" Sentry Glass Plus/3/16" Tempered Glass  Frame:    W-5490mm(216")    H-2553mm(100.5")  Panel:    W-914mm(36")    H-2438mm(96")  DLO:    W-737mm(29")    H-2261mm(89")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: +70/-70 psf</b> Water Penetration Resistance Test Pressure: 430 Pa (9.0 psf) <b>Large Missile Impact Rated</b>

Product Tested By: National Certified Testing Laboratories  
 Report No: NCTL-110-1554901/NCTL-110-15005-1  
 Expiration Date: **October 31, 2031**

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
 MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
 Email: [nami@namiinc.com](mailto:nami@namiinc.com)