

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011273.03-R3  
**DATE:** 12/12/2012  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Solar  
**CODE:** 872-1  
**REVISION DATE:** 11/12/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Solar Innovations, Inc.</b> <b>31 Roberts Road</b> <b>Pine Grove, PA 17963</b>	<b>Series "SI3000 Impact FGW 3x8 Panel"</b> <b>Radius In-Swing Aluminum</b> <b>Folding Glass Wall</b> Configuration: XXXXXX  Glazing: IG-3/16" Tempered Glass (Exterior)/Laminate-3/16" Tempered Glass/0.090" Sentry Glass Plus/3/16" Tempered Glass  Frame: W-5490mm(216") H-2553mm(100.5") Panel: W-914mm(36") H-2438mm(96") DLO: W-737mm(29") H-2261mm(89")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: +60/-80 psf</b> <b>Large Missile Impact Rated</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15540-1/NCTL-110-15005-1  
Expiration Date: **October 31, 2031**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023