

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011280.02-R3
DATE: 07/18/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1
REVISION DATE: 03/19/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, WV 26104	Series "8400" Non-Impact Vinyl Double Hung Window Configuration: X/X Glazing: Insulating Glass (Tempered) Frame: W-1372mm(54") H-1930mm(76") Sash: W-1289mm(50.75") H-946mm(37.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG65 1372 x 1930 (54 x 76)-H Design Pressure: 3112 Pa (65 psf) Negative Design Pressure: 3352 Pa (70 psf) Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 02800597/W-1920
Expiration Date: **March 31, 2030**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023